

## Chhaatrapati Sambhaji Nagar. Municipal Corporation

## FIRE BRIGADE TELPHONE NO-2334000-40FAX No-2331444

Outward No:CSMC/Fire 179 /2024

Date:- 9 / 04 /2024

To, Shri. Siddheshwar Manikrao Aher, Shri/ Gajanan Uttamrao Gavhane, School Building, Gut No. 274/P At. Rajalwadi, Tq. Sillod, Dist. Chhatrapati Sambhaji Nagar.

Sub;- Provisional Fire NOC is issued for the School Building, Gut No. 274/P, At. Rajalwadi, Tq. Sillod, Dist. Chhatrapati Sambhaji Nagar.

Ref;- 1) Your letter Date 10/04//2024 2)CFO Inspection on date 19/04/2024

With Reference to the above subject Provisional Fire NOC is issued to the School Building, Gut No. 274/P, At. Rajalwadi, Tq. Sillod, Dist. Chhatrapati Sambhaji Nagar. Plot area. 10000 Sq.Mtr

Owner has paid Capitation fees Rs. 7,88,050/- & Provisional NOC Fees Rs. 20,000/- in Fire brigade by recipt No 12019, 12020 dated on 18 /04/2024.

Sr. No	Name of Building	Height of Building	Bild No.	Lengt h	Width	No of floors	Total Area of Plot	Built/up area	Fire Fund Rs.	Noc Fees Rs
1	School Building	14.55 Mtr.	1	59.75 Mtr	42.99 Mtr	LG+UG +2 Floors	10000 Sq. Mtr.	6512.80Sq.Mtr Per Sq.Mtr 121/- 788048.80	7,88,050	20000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the **School Building** Shall be provided.

- Open space all around the building shall be provided for free movements of fire tender which will Carry 25 tons weight capacity.
- Over head fire water tank of 10000 ltrs-02 Nos capacity with Main Fire Pump-900 LPM-02 No,& Booster Pump-02 Nos. shall be provided.
- 3. Fire service in let 4 ways incoming shall be provided.
- 4. 08 Nos. Court Yard Hydrant points around the building lire Hose Pipe /Branch shall be provided.
- 5. Wet Riser having hydrant point on all floors with Hose Pipe & Branch shall be provided.
- 6. Hose reel of 100 feet on all out lets shall be provided.
- 7. Fire Extinguisher of ABC & Co2, Fire buckets of suitable capacity shall be provided.
- 8. 01 Nos. Main Staircase 2.00 Mtr.Width & 01 Fire Escape Staircase 2.00 Mtr of shall be provided.
- 9. Manually Operated Electric fire alarm System shall be provided.
- 10 All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency.
- 11 It shall be ensured that security staff & every employes of the building are trained in handing fire fighting equipments & fire fighting.
- 12 Fire Extinguisher, Fire Bucket, Danger, No Smoking, Caution boards should be displayed at the places physically shown & the caution boards should be easily visible from a distance.

- 13 The Fire Safety requirements of IS 3594 I.e. Code of practice for fire safety of Building shall be followed.
- 14 Emergency Telephone numbers like **Police**, **Fire Brigade**, **Hospital**, **Doctors**, should be displayed in security cabin & Office of the building
- 15 Use of all Pipes of TATA Zenith or APL (APPOLO) or ISI Mark for Fire Down comer system shall be Provided
- 16 All the above requirements shall be carried out with prior approval from fire Brigade.

The Fire Fighting System arrangements installed for Existing area, such as Hydrant System, Hose Reel Hose, Fire Extinguishers, Manually Operated Fire Alarm System,

Sr. No.	Fire Fighting Installation	Requirements	Provision	Remarks
1	Portable Fire Extinguishers	Required	IS: 15683 & IS: 2190	Portaable Fire Extinguisher should be installed Confirming to IS 15683 & Other I.S Codes
2	Hose Reel	Required Prominent Places	At Varous Strategic Locations	On each floor in the Staircase landing for fire fighting. The first aiod hose reel shall be connected directly to riser/Down comer main and diameter of the hose reel shall not be less than 19 mm Confirming to IS 884:1985
3	Booster Pump	Required		

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 Reference to above subject Provisional Fire NOC is issued for the Shri. Siddheshwar Manikrao Aher, Shri/ Gajanan Uttamrao Gavhane, School Building, Gut No. 274/P, At. Rajalwadi, Tq. Sillod, Dist. Chhatrapati Sambhaji Nagar.

Chief Fire Officer

Municipal Corporation Chhatrapati Sambhaji Nagar.

Copy to:- D.D T P. Municipal Corporation, Chhatrapati Sambhaji Nagar

PRINCIPAL

ERA Nexus International School Sillod, Tg. Sillod Dist. Chh. Sambhajinagar

MANAGER

ERA Nexus International School Sillod, Tq.Sillod Dist.Chh.Sambhajinag...

Shri Dnyaneshwar Shikshan Prasarak Mandal